

| FLAMMABLE AND COMBUSTIBLE MATERIALS CHECKLIST (OSHA)   |     |     |    |                           |
|--|-----|-----|----|---------------------------|
| THINGS TO LOOK FOR   | N/A | YES | NO | REMARKS/ACTION TAKEN/DATE |
| Combustible scrap, debris, and waste materials (oily rags, etc.) are stored in covered metal receptacles and removed from the worksite promptly.                                     |     |     |    |                           |
| Proper storage is practiced to minimize the risk of fire including spontaneous combustion.   |     |     |    |                           |
| Approved containers and tanks are used for the storage and handling of flammable and combustible liquids.  |     |     |    |                           |
| All connections on drums and combustible liquid piping, vapor and liquid are tight.  |     |     |    |                           |
| All flammable liquids are kept in closed containers when not in use (for example, parts cleaning tanks, pans, etc.).   |     |     |    |                           |
| Bulk drums of flammable liquids are grounded and bonded to containers during dispensing.   |     |     |    |                           |
| Storage rooms for flammable and combustible liquids have explosion-proof lights.   |     |     |    |                           |
| Storage rooms for flammable and combustible liquids have mechanical or gravity ventilation.  |     |     |    |                           |
| Liquefied petroleum gas is stored, handled, and used in accordance with safe practices and standards.  |     |     |    |                           |
| “NO SMOKING” signs are posted on liquefied petroleum gas tanks.  |     |     |    |                           |
| Liquefied petroleum storage tanks are guarded to prevent damage from vehicles.   |     |     |    |                           |
| All solvent wastes and flammable liquids are kept in fire-resistant, covered containers until they are removed from the worksite.  |     |     |    |                           |
| Fuel gas cylinders and oxygen cylinders are separated by distance and fire -resistant barriers while in storage.   |     |     |    |                           |
| Fire extinguishers are selected and provided for the types of materials in areas where they are to be used.  |     |     |    |                           |
| Appropriate fire extinguishers are mounted within 75 feet of outside areas containing flammable liquids, and within 10 feet of any inside storage area for such materials.           |     |     |    |                           |
| Extinguishers free from obstructions or blockage.  |     |     |    |                           |
| All extinguishers are serviced, maintained, and tagged at intervals not to exceed one year.  |     |     |    |                           |
| All extinguishers are fully charged and in their designated places.  |     |     |    |                           |
| Where sprinkler systems are permanently installed, the nozzle heads are so directed or arranged that water will not be sprayed into operating electrical switchboards and equipment. |     |     |    |                           |
| “NO SMOKING” signs are posted where appropriate in areas where flammable or combustible materials are used or stored.  |     |     |    |                           |
| Safety cans are used for dispensing flammable or combustible liquids at a point of use.  |     |     |    |                           |
| All spills of flammable or combustible liquids are cleaned up promptly.  |     |     |    |                           |

| <b>FLAMMABLE AND COMBUSTIBLE MATERIALS CHECKLIST (OSHA)</b>   |            |            |           |                                      |
|---|------------|------------|-----------|--------------------------------------|
| <b>THINGS TO LOOK FOR</b>   | <b>N/A</b> | <b>YES</b> | <b>NO</b> | <b>REMARKS/ACTION<br/>TAKEN/DATE</b> |
| Storage tanks are adequately vented to prevent the development of excessive vacuum or pressure as a result of filling, emptying, or atmosphere temperature changes. |            |            |           |                                      |
| Storage tanks are equipped with emergency venting that will relieve excessive internal pressure caused by fire exposure.  |            |            |           |                                      |
| “NO SMOKING” rules are enforced in areas involving storage and use of hazardous materials.  |            |            |           |                                      |
| <b>Inspector:</b> _____ <b>Organization:</b> _____ <b>Date:</b> _____   |            |            |           |                                      |